

Proforma for safe drinking water and sanitary condition certificate

No : 6/2022-23

Dated 16.05.23

It is certified that an inspection team headed by Dileepkumar N U Health inspector Community Health Centre Vadavucode, Ernakulam district inspected the BTC Public School and the campus Puthencruz, Ernakulam on 16.05.2023 and found that the BTC Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the central/state/U.T. Govt.

The above is valid for a period of one year only.



Signature with seal:



HEALTH INSPECTOR
HC - VADAVUCODE

Name: Dileepkumar N U

Designation : Health Inspector

Community health centre Vadavucode, Ernakulam




Dr. Vinod Paulose
MEDICAL OFFICER IN CHARGE
COMMUNITY HEALTH CENTRE
VADAVUCODE




PRINCIPAL
BTC Public School
Puthencruz - 682 308


MANAGER
B. T. C. PUBLIC SCHOOL
PUTHENCruz - 682 308

KERALA WATER AUTHORITY

Office of the Assistant Engineer,
Quality Control SubDistrict Lab,
Ankamaly: 683 101
Ph. / Fax-0484-2623576
Email:
qcsdlankamaly@gmail.com

No. AE-QCSDL/ANK/23-24

Dated: 15.05.2023

From

The Assistant Engineer.

To

BTC Public School
Puthencruz,
Ernakulam

Sir,

Sub: Water sample test result-forwarding – Reg.
Ref: Letter No. NIL & Application ID-.QUA_60019 dt 09.05.2023

I am forwarding here with the test result of analysis of water handed over to this lab on 10.05.2023.

Acc: As above

Yours faithfully,



FOR ASSISTANT ENGINEER





KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER ANALYSIS REPORT

REPORT NO: ANK/BC138/S/2023

Report of Issue Date: 15.05.2023

Customer Name & Address BTC PUBLIC SCHOOL PUTHENCRUZ P O, ERNAKULAM		Date of Receipt of Payment	09.05.2023	
		Date of Sample received	10.05.2023	
		Sample Given by	Customer	
		Sample Code	ANK/BC138/S/2023	
		Sample Name	Water	
		Sample Condition	Good	
		Source of Sample	WELL	
		Sample Quantity	200 ml	
		Test performing dates : 10.05.2023 From: 12.05.2023		
Sl. No.	Source	No of Coliforms per 100ml of sample	E.Coli in 100ml of sample	
1	Water sample submitted by the customer	43cfu/100ml	3cfu/100ml	

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

End of Report

KWA/QCSDL/ANK/01-2022		Issue Date : 01.06.2022	
Rev.No: Nil	Rev.Date : Nil	Page 1 of 1	

