



OFFICE OF THE STATION OFFICER

FIRE AND RESCUE STATION PATTIMATTOM

No. C-307/2023

Dated:15/09/2023

NO OBJECTION CERTIFICATE

(RENEWAL)

The Board headed by the Station Officer, Fire & Rescue Station Pattimattom, had inspected the **Educational Building**, 3 Floors (G+2) 11.58 mtr, with total plinth area of 4288.62 Sqm in Re-survey No.347/1-3, 347/2-2, 347/1-2 in **Puthencruz village** in Ernakulam District under **Vadavucode Puthencruz Gramapanchayath** owned by **Sr.Yohanna, BTC Public School, St. Marys Convent, Puthencruz.P.O, Ernakulam, Kerala, PIN – 682 308**. And recommended to Renew No Objection Certificate No. FRS/07/PTMT/9104/2022/FINAL Dated 23/07/2022 of **Regional Fire Officer, Fire and Rescue Services, Ernakulam**, for the occupation of the said building as per report No: C-307/2023 Dated 15/09/2023 of the Station Officer Fire & Rescue Station, Pattimattom for One year.

2. In the Circumstances, this No Objection Certificate is issued under my seal and authority for the continued occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.

3. This Certificate is issued on the condition that the fire fighting systems installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition. **This certificate is valid for one year from the date of issue. After One year the certificate must be renewed. Non renewal of the certificate with in the time limit will result in loss of eligibility for insurance coverage and and appropriate legal action by the local self Government/Revenue Department.** All officers of and above the rank of station officers of the Fire & Rescue services Department will have the right to inspect the building on any day/time after serving **7 days notice** to ensure that the installed systems are in good working condition.



STATION OFFICER
FIRE & RESCUE STATION
PATTIMATTOM

To,

The party.

Copy to :

The SecretaryPanchayath.

